

FLAMMABLE & COMBUSTIBLE MATERIALS

Company Name: _____ Facility Address: _____

Manager/Supervisor: _____ Date/Time: _____

Inspector(s): _____

Yes	No	N/A	Corr Date	Area Inspected
				<ol style="list-style-type: none">1. Combustible materials stored in covered metal receptacles and removed from work areas promptly?2. Approved containers and tanks used for the storage and handling of flammable and combustible liquids?3. Flammable liquids kept in closed containers when not in use?4. Are bulk drums of flammable liquids grounded and bonded to containers during dispensing?5. Storage rooms have explosion-proof lights and adequate ventilation?6. No smoking signs posted on liquefied petroleum gas tanks and in areas where flammable or combustible materials are used and stored?7. Fuel gas cylinders and oxygen cylinders separated by distance, fire resistant barriers, etc. while in storage?8. Spills of flammable or combustible liquids cleaned up promptly?9. Storage tanks adequately vented to prevent the development of excessive vacuum or pressure?

Date